



CITY OF ATLANTA

OFFICE OF INSPECTOR OF BUILDINGS

800 CITY HALL

Atlanta, Georgia 30303

WILLIAM R. WOFFORD, P.E., R.A.
INSPECTOR OF BUILDINGS

CHARLES M. SMITH, E.E.
ASST. INSPECTOR OF BUILDINGS

March 21, 1969



*duw
OK*

MEMORANDUM

TO: The Honorable Ivan Allen, Jr.

FROM: W. R. Wofford *W. R. Wofford*

RE: Suggested reply of letter to Mr. Jack W. Crissey

I have your letter of March 18, 1969, with reference to the testing of gas piping.

The Building Departments Chief Plumbing Inspector, Mr. Mitchell and Mr. Spurlin of the Heating Division have reviewed your letter together with the previous letter you wrote concerning gas piping and advises that the ordinance to which you refer does not require testing on existing gas lines and that only new gas lines installed is required to be tested and approved before it is used.

Mr. Mitchell, Chief Plumbing Inspector, advises that he has discussed this matter with Mr. Hansen of your firm, who is a member of the Plumbing Examining Board and is familiar with the aforementioned provisions. The matter has also been discussed and approved by the Plumbing Advisory Board. I want to assure you of our cooperation in anyway possible but I believe you have misinterpreted the ordinance.

If you desire any additional information, the Building Department will be glad to provide it for you.