



CITY OF ATLANTA

DEPARTMENT of CONSTRUCTION

301 CITY HALL

Atlanta 3, Georgia

July 19, 1967

RAY A. NIXON
Chief of Construction

RICHARD W. RESPES
ASST. CHIEF OF CONSTRUCTION

ROBERT H. MORRIS
ASST. CHIEF OF CONSTRUCTION

MEMO

TO: Ray A. Nixon - Director of Public Works

FROM: Ken Lancaster

As directed, an investigation was made at #555 East Anthony Street N. W. to determine if we could be of assistance in the solution of a flood problem.

We found that storm water from the streets does not flow into this drain ditch, and, therefore, responsibility by this Department cannot be justified. However, there is a great volume of storm water flowing into this ditch from City property belonging to the Parks Department. I believe, it would relieve the problem of this ditch overflowing onto this person's property if this water was intercepted and directed to Proctor Creek. This could be accomplished by constructing a bunker at the top of the small ditch bank or by the grading of a small berm ditch parallel to the existing one.

RKL/pae

