

Work Late Up
Mrs. Annie B. Laird 7/26/69 1 Unit 662 Mayland Ave. S.W. (1)

All work to be done shall comply with specifications set forth in "Invitations to Bid" and "Minimum Property Standards for Urban Renewal Rehabilitation".

NOTE: Item number corresponds to item in specifications. Items left out
numbers are not included.

ITEM NO.

ACTUAL VIOLATIONS

left

- 21 Repair driveway and repair curb-wall of drive ^{soil} ~~soil~~.
- 20-22 Repair exterior siding and all damaged connecting members, install boxed in eaves of 3/8" exterior plywood, install eaves vents not more than 5'0" apart and apply (2) coats exterior oil base paint to entire exterior.
- 18 Point up morter joints in foundation and curtain walls and apply masonry paint.
- 18 Repair and paint steps around house.
- 4 Repair and reglaze all windows and paint.
- 17 ^{House} Install (22) aluminum window screens.
- 18 Repair foundation vents.
- 7 Rewire house to comply with city electrical code and our standard.
- 11 Install new door and frame to basement.
- 18 Repair retaining wall on right side of premises.
- 10 Treat for termites and other infestations.
- 13 Reroof house with staple lock shingles.
- 7 Install ceiling light and wall switch to basement step.
- Repair chimney.
- Demolish garage in rear of premises and haul away debris and trash from premises.
- 11 Repair front gable, install 1" x 12" sheathing vertically and strip joints with 1" x 2" and paint (2) coats two tone paint.

ITEM NO.

- 1-3 Strip ceiling with 1" x 4" and install 1/2" sheetrock on ceiling and walls and paint with (2) coats paint.
- 2 Sand floor, fill cracks and apply (2) coats varnish.
- 4 Rework (4) windows to open and close freely.
- Rework front door to open and close freely.