

Building

February 24, 1969

Mr. Jack W. Crissey
Fulton Plumbing Company
443 Stonewall Street, S.W.
Atlanta, Georgia 30313

Dear Mr. Crissey:

With further reference to your letter of February 14, Mr. Wofford reports that there is some misinterpretation of the ordinance.

He reports that the ordinance does not require that existing appliances be disconnected in order to test heretofore installed gas lines in buildings, but the ordinance does require that any new gas line installed be tested and approved before it is used. Pressure tests on existing gas lines will not be required.

I hope that this clarifies the ordinance, and should you need any additional information, I am sure Mr. Wofford will be happy to be of assistance.

Sincerely,

Ivan Allen, Jr.