



CITY OF ATLANTA

OFFICE OF INSPECTOR OF BUILDINGS

800 CITY HALL

Atlanta, Georgia 30303

June 12, 1967



WILLIAM R. WOFFORD, P.E., R.A.
INSPECTOR OF BUILDINGS
ELMER H. MOON, E.E., P.E.
ASST. INSPECTOR OF BUILDINGS

Mr, Dan, E. Sweat, Jr.
Director of Governmental Liaison
Mayor's Office
Atlanta, Georgia

RE: 561 - 573 West Peachtree Street
Life of Georgia Building

Dear Mr. Sweat:

An inspection of the above building made June 9, 1967, revealed that the following items will have to be corrected before a State Certificate of Occupancy can be issued.

1. An alarm system will have to be installed.
2. An additional stand pipe must be installed.
3. Additional hose cabinets must be installed with this stand pipe.
4. Additional exit lights and directional signs are needed.
5. The rail on the fire escape will have to be four feet in height.

I hope that this will provide you with all the information which might be needed to determine if the Community Chest Agencies would desire to use the building.

Very truly yours,

W.A. Hewes
Chief Building Inspector

WAH:rs1